



City of Destin

4200 Two Trees Road • Destin, Florida 32541
Telephone (850) 837-4242 • Fax (850) 837-3267 • E-mail: cityhall@destin.net

January 26, 2001

Order No. 01-01

Final Development Order:

**“JUST-RITE SUPPLY WAREHOUSE”:
A MINOR DEVELOPMENT
(SP-00-56)**

Based upon the City's approval of this Development Order, on January 12, 2001, this document will serve as your Final Development Order, to include all of the provisions of the attached Technical Review Committee Report and with the following conditions, as specified by the Technical Review Committee:

BACKGROUND / ISSUE:

Applicant: Campbell Engineering, Inc., on behalf of Clark Investments of Destin, L.L.C.
Location: The proposed project is located at 4648 Gulfstarr Drive.
Request: Approval of a Minor Development identified as “Just-Rite Supply Warehouse.”
The proposed project consists of a 7,644 square foot warehouse facility.
Parcel Size: The subject property contains 0.39 acres, more or less.
Future Land Use: Mixed Use (MU)
Zoning District: Business Tourism (BT)
Density: Not applicable
Intensity: Allowed: 1.07 Floor Area Ratio
Proposed: 0.48 Floor Area Ratio
Application Date: October 5, 2000
TRC Date: November 15, 2000
Approved Site Plan Date: January 12, 2001

DETERMINATIONS:

1. All the findings and requirements of the Technical Review Committee report dated January 12, 2001, are incorporated herein.

Community Development ♦
(850) 837-5686
Fax: (850) 837-7949

Engineering ♦
(850) 837-5694

Building Inspections ♦
(850) 654-1119
Fax: (850) 837-7949

Public Works
(850) 837-6869

Community Center ♦
(850) 654-5184
Fax: (850) 654-8998

Library
(850) 837-8572
Fax: (850) 837-5248

CONDITIONS OF APPROVAL FOR THE "JUST-RITE SUPPLY WAREHOUSE": A MINOR DEVELOPMENT (SP-00-56):

Pursuant to the City of Destin Land Development Code and the City of Destin Code of Ordinances:

1. Construction must commence within twelve (12) months of approval of the Final Development Order on January 12, 2001 (no later than January 12, 2002), and must be completed as shown on plans approved by the Technical Review Committee (stamp dated January 12, 2001).

WARNING: If the applicant/owner has not obtained a construction permit(s) within 365 days of issuance of the final development order, the final development order is void and the application for plan approval must be re-initiated.

NOTE: An applicant/owner who desires to extend the twelve (12) month deadline shall submit a request to the Community Development Department, no less than sixty (60) days prior to the expiration of the twelve (12) month deadline to obtain a construction permit. The applicant /owner should review Article 2, Section 2.15.00, of the Destin Land Development Code for further explanation of the Development Order extension process.

2. If the applicant fully complies with the requirements of Condition Number 1 above, the concurrency status for "Just-Rite Supply Warehouse" is protected for five (5) years through January 12, 2006. The protected concurrency status, however, will be lost if:
 - A. Construction activity ceases for a period exceeding one (1) year at any time during the term of this Final Development Order, or
 - B. Construction permit(s) are not obtained in accordance with Section 2.09.00 of the Land Development Code to maintain concurrency.
3. The applicant must obtain City of Destin permits for the following activities on and off site (These may require appropriate bonding):
 - A. Disturbance of the City's right-of-way.
 - B. Pavement cuts.
 - C. Construction of any kind.
 - D. Clearing, grubbing, or demolition.
 - E. Paving, grading, drainage, sidewalks.
 - F. Signage.
 - G. Installation of utilities.
 - H. Construction trailers.
4. Prior to the issuance of any City Permit, all outstanding costs associated with this project that are owed to the City must be paid in full.

5. Prior to the issuance of a Clearing Permit, a clearing plan must be submitted and approved by the Community Development Department.
6. Prior to the issuance of a Certificate of Occupancy, all required parking and related landscaping shall be installed, inspected, and approved by the Engineering and Community Development Departments.
7. Prior to the issuance of a Certificate of Occupancy, all applicable impact fees must be paid.
8. If the applicant proposes outdoor lighting in the future, an outdoor lighting plan must be submitted to the Community Development Department for review and approval.
9. If groundwater is observed standing in the stormwater structures, the stormwater management plan shall be void and a revised stormwater plan must be resubmitted for review and approval.

TECHNICAL REVIEW COMMITTEE REPORT

“JUST-RITE SUPPLY WAREHOUSE”: A MINOR DEVELOPMENT (SP-00-56)

TRC Report: January 12, 2000

ISSUE:

Applicant: Campbell Engineering, Inc., on behalf of Clark Investments of Destin, L.L.C.
Location: The proposed project is located at 4648 Gulfstarr Drive.
Request: Approval of a Minor Development identified as “Just-Rite Supply Warehouse.”
The proposed project consists of a 7,644 square foot warehouse facility.
Parcel Size: The subject property contains 0.39 acres, more or less.
Future Land Use: Mixed Use (MU)
Zoning District: Business Tourism (BT)
Density: Not applicable
Intensity: Allowed: 1.07 Floor Area Ratio
Proposed: 0.48 Floor Area Ratio
Application Date: October 5, 2000
TRC Date: November 15, 2000
Approved Site Plan Date: January 12, 2001

DISCUSSION/FINDINGS:

Campbell Engineering, Inc., on behalf of Clark Investments of Destin, L.L.C., is requesting approval of a Minor Development identified as “Just-Rite Supply Warehouse.” The proposed project consists of a 7,644 square foot warehouse facility. The proposed project is located at 4648 Gulfstarr Drive. The subject property contains 0.39 acres, more or less.

COMPREHENSIVE PLAN/ZONING:

The property has a Future Land Use Designation of Mixed Use (MU) and a Zoning Designation of Business Tourism (BT). The proposed use is consistent with these land use regulations.

COMPATIBILITY:

The surrounding properties are as follows:

<u>FLU</u>	<u>Zoning</u>	<u>Existing Use</u>
North: Mixed Use	Business Tourism	Commercial
South: Mixed Use	Business Tourism	Single-family dwellings
East: Mixed Use	Business Tourism	Vacant
West: Mixed Use	Business Tourism	Commercial

The project, as required by the Comprehensive Plan and the Land Development Code, has undergone a compatibility review and meets the minimum requirements.

DENSITY:

Not applicable.

HEIGHT:

The BT Zoning District does not have a maximum building height. Building height in this district is determined by a compatibility analysis. The proposed height of the building to the top of the highest roof, as seen from the front elevation, is twenty-one (21) feet, more or less.

FLOOR AREA RATIO:

The project has a 0.48 Floor Area Ratio, which is less than the maximum of 1.07 allowed.

RIGHT-OF-WAY DEDICATION:

There is no right-of-way dedication involved with this project.

CONCURRENCY MANAGEMENT:

Concurrency requirements have been met:

Potable Water: X Roadways: X Solid Waste: X
Recreation: X Sewer: X Drainage: X

TRAFFIC ANALYSIS:

According to the traffic review conducted by the City's traffic consultant, the proposed development will generate 3 PM Peak Hour directional trips on Segment "C" of U. S. Highway 98. Segment "C" currently has 33 PM Peak Hour directional trips available. There will be 30 PM Peak Hour directional trips remaining for Segment "C." Therefore, traffic concurrency is satisfied for this project, as confirmed by the City's traffic consultant.

SUBDIVISION OR PUD - PLAT:

Not applicable.

AIRPORT PROTECTION:

The subject site is located within the airport protection area.

NOTE: If construction necessitates the use of a crane, or other obstruction, which exceeds Federal Aviation Administration FAR 77 Standards (normally 200 feet above ground level), the applicant must request a variance from FAA for temporary encroachment into this restrictive area and a copy of completed FAA Form 7460, must be placed on file with the City of Destin prior to the crane, or other obstruction, penetrating the restricted airspace.

SETBACKS:

	<u>Required</u>	<u>Buffers</u>	<u>Provided</u>
Front (southern):	None	10' FP	64.2' including 10' FP
Side (eastern):	None	5' CB	10' including 5' CB
Side (western):	None	5' CB	10' including 5' CB
Back (southern):	None	10' VB	10' VB
Between Bldgs:	N/A	N/A	N/A

Note: 10' FP = 10' Front Perimeter Landscape Area, 5' CB = 5' Common Boundary Buffer, and 10' VB = 10' Vegetative Buffer. A 5' Common Boundary Buffer is required along the western and eastern property lines, a 10' Front Perimeter Landscape Area is required along the northern, and a 10' Vegetative Buffer is required along the southern property line.

WHITE SANDS ZONE:

The proposed project is not located within either White Sand Zone 1 or 2.

SIGNS:

No signs have been proposed with this project. All future signs must comply with the sign code section of the Destin Land Development Code in effect at the time a sign application is submitted.

COX COMMUNICATIONS:

Cox Communications approved the project at the November 15, 2000, TRC meeting.

DESTIN FIRE CONTROL DISTRICT:

Destin Fire Control District approved the project in letters dated November 15, 2000, and December 22, 2000.

GULF POWER:

Gulf Power approved the project in a letter dated November 14, 2000.

OKALOOSA GAS:

Okaloosa Gas approved the project in a letter dated November 15, 2000.

SPRINT:

Sprint approved the project in a letter dated November 13, 2000.

UNIVERSALCOM/NEWSOUTH:

UniversalCom/NewSouth approved the project in a letter dated November 15, 2000.

WATER/SEWER PROVIDER:

Destin Water Users, Inc., approved the project in a letter dated November 14, 2000.

UTILITIES:

All utilities are required to be underground.

STORMWATER:

The City Engineer approved the stormwater plan in a memo dated January 10, 2001.

INGRESS/EGRESS:

Access to the property is provided by one twenty-seven (27) foot wide two-way drive onto Gulfstarr Drive.

SIDEWALKS:

A section of five (5) foot sidewalk must be installed along the property adjacent to Gulfstarr Drive.

REFUSE COLLECTION:

Refuse collection is provided by a single enclosed dumpster located on-site as shown on the approved site plan.

LANDSCAPE:

The project meets or exceeds the landscape requirements of the Destin Land Development Code as indicated on the approved plans and as follows:

Open Space Requirements:

17,064 sq. ft. of property x 18% = 3,072 sq. ft. required
Site plan provides 23.7% = 4,038 sq. ft. provided

Tree Requirements:

Credits for Existing Trees (2" to 6" diameter) on Site (0 trees x 2 credits per tree):	0
Credits for Existing Trees (7" to 12" diameter) on Site (0 trees x 3 credits per tree):	0
Credits for Existing Trees (13" to 19" diameter) on Site (0 trees x 4 credits per tree):	0
Credits for Existing Trees (20" or 24" diameter) on Site (0 trees x 5 credits per tree):	<u>0</u>
Total Reforestation Credits for Existing, Protected, or Preserved Trees:	<u><u>0</u></u>
Reforestation Trees (1 per every .10 of an acre: 0.40 x 10 = 4) Required on Site:	<u>4</u>
Total Reforestation Credits for Trees Required (4 – 0 = 4 (0) remaining credits):	<u>0</u>
Total Reforestation Trees Required on Site:	<u><u>4</u></u>
Total Reforestation Trees (1 per every .10 of an acre minus credits) Required on Site:	4
Replacement Trees (removal of trees over 12" d.b.h.) Required on Site:	0
Perimeter Trees (1 per 25') Required on Site:	4
Parking Lot Trees (1 per end row and landscape island) Required on Site:	2
Vegetative Buffer Trees, if applicable, (1 per 25') Required on Site:	4
TOTAL TREES REQUIRED:	<u><u>14</u></u>
TOTAL TREES PROVIDED:	<u><u>14</u></u>

A 5' Common Boundary Buffer is required along the western and eastern property lines, a 10' Front Perimeter Landscape Area is required along the northern property line, and a 10' Vegetative Buffer is required along the southern property line. The required five (5) foot Common Boundary Buffer shall provide a minimum of fifty (50) percent opacity for that area between the finished grade level at the common boundary line and six (6) feet above said level and horizontally along the length of all common boundaries within three (3) years of planting. All required trees must be a minimum of six (6) feet high at time of planting and reach a crown of twenty (20) feet at maturity. If the twenty (20) foot crown requirement is not met, additional trees shall be added and grouped together to meet the twenty (20) foot crown. If shrubs are used in the required buffer areas, they must be a minimum of twelve (12) inches in height when measured immediately after planting. **WARNING: A Certificate of Occupancy will not be issued until the required landscape material has been inspected and approved by the Community Development Department.**

PARKING:

The project meets or exceeds the parking requirements as follows:

Per code:

Warehouse/storage: 1 space for every 1,000 square feet of gross floor area.

Per site plan:

Warehouse/storage: 7,644 square feet / 1,000 = 8 spaces

TOTAL REQUIRED: 8 spaces

TOTAL PROVIDED: 8 spaces (includes 1 handicap parking space per the approved site plan)

LOADING SPACE (ZONE):

Per code:

Commercial: 1 loading space is required (10 feet wide and 25 feet long with 15 foot clearance) for the first 10,000 sq. ft. of gross floor area, and one space for each additional 20,000 sq. ft.

Per site plan:

Commercial: 1 loading space is required (10 feet wide and 25 feet long with 15 foot clearance) for 7,644 sq. ft. of gross floor area.

TOTAL REQUIRED: 1 loading space

TOTAL PROVIDED: 1 loading space

One 10' x 25' loading space is provided within the warehouse facility.

STATE/FEDERAL PERMITS REQUIRED BEFORE ISSUANCE OF BUILDING PERMIT:

1. A Florida Department of Environmental Protection general notice permit (for stormwater) has been issued for this site and is on file.

IMPACT FEES:

The owner/applicant must pay the following impact fees prior to the issuance of a Certificate of Occupancy:

Police Protection: The police protection impact fees were calculated using the “Industrial per 1,000 sq. ft. = \$5.87” fee amounts under the “Non-residential –Outside Corridor” category.

$$(7,644 \text{ sq. ft.}) \times (\$5.87) = \$44,870.28 / 1,000 = \underline{\$44.87}$$

(sq. ft. of building) x (Industrial per 1,000 sq. ft. fee amount) = (figure) / (per 1,000 sq. ft.) = Impact Fee

Total Police Impact Fees to be paid for “Just-Rite Supply Warehouse”: \$44.87

Road: The road impact fees were calculated using the “Warehouse/Storage” (per 1,000 sq. ft.) = \$214.00 fee amounts.

$$(7,644 \text{ sq. ft.}) \times (\$214.00) = 1,635,816 / 1,000 = \underline{\$1,635.82}$$

(sq. ft. of building) x (Warehouse/Storage per 1,000 sq. ft. fee amount) = (figure) / (per 1,000 sq. ft.) = Impact Fee

Total Road Impact Fees to be paid for “Just-Rite Supply Warehouse”: \$1,635.82

Parks: (not applicable)	=	\$0.00
Public Library: (not applicable)	=	\$0.00
Police Protection:	=	\$44.87
Roads:	=	\$1,635.82
TOTAL:		<u>\$1,680.69</u>

OTHER FEES:

The fees listed below are based on the most recent information available and are required to be paid by the applicant as part of the cost recovery associated with the proposed project:

City Compatibility Expert:	Not utilized	Planning Commission Advertising:	Not applicable
City Traffic Consultant:	\$104.51 (paid)	City Council Advertising:	Not applicable
City Surveyor:	Not utilized		

COMMENTS:

Public Input:

There have been no comments of support or opposition filed with Staff regarding this project.

Per Community Development Department:


1. Prior to the issuance of any City Permit, all outstanding costs associated with this project that are owed to the City must be paid in full.
2. Prior to the issuance of a Clearing Permit, a clearing plan must be submitted and approved by the Community Development Department.
3. Prior to the issuance of a Certificate of Occupancy, all required parking and related landscaping shall be installed, inspected, and approved by the Engineering and Community Development Departments.
4. Prior to the issuance of a Certificate of Occupancy, all applicable impact fees must be paid.
5. If the applicant proposes outdoor lighting in the future, an outdoor lighting plan must be submitted to the Community Development Department for review and approval.

Per Engineering Department:


1. If groundwater is observed standing in the stormwater structures, the stormwater management plan shall be void and a revised stormwater plan must be resubmitted for review and approval.

UNRESOLVED ISSUES:

None.



Gerald F. Mucci, Date
Community Development Director



Clark Investments of Destin L.L.C. Date
Owner
Guy Clark,
President